



Idaho Surveying & Rating Bureau, Inc.

1871 South Cobalt Point Way
Meridian, Idaho 83642

Tel: (208) 343-5483
FAX: (208) 895-8059

www.isrb.com
e-mail info@isrb.com

Alfred C. Frieze, CPCU
Secretary - General Manager

December 1, 2009

Bill McCabe, Fire Chief
North Bench Fire Department
Highway 2 / 3 Mile
Bonners Ferry, Idaho 83805

RE: Results of the ISRB Public Protection Classification Evaluation

Dear Chief McCabe:

Thank you for your assistance with the evaluation of the North Bench Fire Department. Based on this evaluation the following results will be made available to the companies using the services of the Idaho Surveying & Rating Bureau, Inc.:

Location of property to be insured.	Public Protection Class for Dwelling and Homeowners	Public Protection Class for Commercial Property and Farms
Within 1000 ft of a fire hydrant/pumper connection on one of the water systems listed below	5	5
Within 5 miles of a fire station listed below	8	9
Between 5 & 10 miles to a fire station listed below	9	9
Over 10 miles to a fire station listed below	10	10
Listed Water Systems:	Bee Line Water System, 3 Mile Water System	
Listed Fire Stations:	Highway 2 @ #mile Junction, Camp 9 Rd. and Highway 95, 28 Little Bear	

These public protection classes will be effective February 1, 2010.

The classifications listed above are not applicable to those properties with a Needed Fire Flow greater than 3,500 gallons per minute. Those properties, if any, will be evaluated on an individual basis and may vary from the classes listed above.

The purpose of this evaluation is to determine a property insurance classification. The evaluation was not conducted for property loss prevention or life safety purposes and no life safety or property loss prevention recommendations will be made. The numerical classes are a property insurance pricing tool. The results of this evaluation is not intended to analyze all aspects of a comprehensive public protection program and should not be used for purposes other than insurance pricing.

Please find a *Fire Suppression Rating Schedule* Report.

I would like to thank you for the courtesies extended to me during my visit.

If I can be of further assistance, please feel free to contact me.

Sincerely,

Douglas H. Young
Field Rating Representative

enclosures